

PRODUCT CERTIFICATE OF REGISTRATION



Global Certification Pty Ltd

Number 575

Product Performance Testing

AS 1546.3:2017

**Advanced Secondary 5000 Litre/day or 33.3EP Level
without Nutrient Reduction**

Issued to

Wastewater Australia Pty Ltd

321 New England Highway, Rutherford, NSW 2320

Certification Date: - 4/7/2020

Expiry Date: - 3/7/2025

Product Certified:

Model	Disinfection	Average Results over the Test Period	Servicing Frequency	Discharge	Manufactured and assembled
Garden Master Elite 5000	Yes	TSS 6.7mg/l BOD ₅ <2mg/l Turbidity 10.3NTU FAC 2.3 mg/l E coli <1CFU/100ml	3 Monthly Service sedimentation pump out 4.8 years or as required	Pumped via disinfection/pump chamber with chlorine dispenser	Manufactured and Assembled: 65 Warradale Road, Warragamba NSW 2752

The system took 2 weeks to meet the advanced secondary standard.

NACE CODES: 3700

This Certificate of Conformance to the Product Certificate Scheme remains the property of Global Certification Pty. Ltd. and is granted subject to the terms and conditions of the Contract Application, in respect of the Product certified on this page and the attached schedule to the Certification of Conformance, bearing the same number as this certificate.

Date of Issue: 4th July 2020 **Bruce Smith Director**



www.jas-anz.com.au/register

Signed for and on behalf of Global Certification Pty Ltd

PO Box 953 Belconnen ACT 2616

